


NOTES:

1. JOINTS COMPLETELY ENCASED IN CONCRETE MAY BE SOLVENT WELD POLYVINYL CHLORIDE SLIP ON JOINTS.
2. STUB PIPE AND DROP PIPE TO BE SAME SIZE.
3. CONCRETE ENCASEMENT TO EXTEND TO MIDPOINT OF STUB PIPE.
4. EXTERNAL DROP IS REQUIRED WHEN INVERT OF THE INCOMING PIPE IS 24" OR GREATER ABOVE THE INVERT OF THE MANHOLE.
5. SEE CONSTRUCTION DRAWINGS FOR POLYVINYL CHLORIDE PIPE SIZE, STANDARD DIMENSION RATIO, AND PIPE STIFFNESS REQUIREMENTS.
6. POLYVINYL CHLORIDE PIPE 4" THROUGH 15" SHALL CONFORM TO THE AMERICAN SOCIETY FOR TESTING AND MATERIALS STANDARD D3034.
7. POLYVINYL CHLORIDE PIPE 18" AND LARGER SHALL CONFORM TO THE AMERICAN SOCIETY FOR TESTING AND MATERIALS STANDARD F679.



City of Rio Rancho
Department of Public Works

DROP MANHOLE CONNECTION

DATE MODIFIED:

APRIL 2016

DWG. NO. S-10

APRIL 22, 2016